

(BIS/NABL ACCREDITED LABORATORY)

19/168, Sarai Rohilla, Old Rohtak Road, Near Shastri Nagar Metro & Usha Mata Mandir, Delhi-110035 Tel. 011-23643995, Fax: 011-23643992 (M) 9582782444, Email: info@atncc.in; amittestcc@gmail.com

TEST REPORT

ADDDECC	OF THE	LABORATORY ·
ALLITON		I ABURATURY

TELEGRAM: TELEPHONE(S):

FAX: E-mail:

TEST REPORT AS PER IS 14255: 1995

REPORT NO: ATCC2015031903

Issue To: Finecab Wires & Cables Pvt. Ltd. 2-3-465/7, Minister Road, Secunderabad-500003

(ELECTRICAL LABORATORY)

19/168, Basti Sarai Rohilla, Old Rohtak Road, Near Usha Mata Mandir, Gurudwara Wali Gali, Delhi -110035

011-23643995, 011-23643992

011-23643992 info@atncc.in

[WITH AMENDMENT NO(s) 1]

DATED: 19.03.2015

ART A. PARTICULARS OF SAMPLE SUBMITTED

a) Nature of Sample:

Aerial Bunched Cable for working voltages upto and

including 1100Volts

b) Grade/Variety/Type/Class/Size etc:

3Cx95 sq.mm Stranded Circular Compacted Aluminium Phase Conductor XLPE insulated + 1Cx16 sq.mm Stranded Circular Compacted Aluminium Street Light Conductor XLPE insulated + 1Cx 70 sq.mm Stranded Circular Compacted Aluminium Alloy Bare Messenger Conductor, LT Aerial Bunched Cable, 1100 Volts grade, 5 meters Bare aluminium wire Dia. 2.55 mm for tensile strength and wrapping test before stranding,

5 meters Bare aluminium wire Dia. 1.74 mm for tensile strength and

wrapping test before stranding,

5 meters bare aluminium alloy wire Dia. 3.57 mm for elongation test

before stranding.

c) Declared Values, if any:

d) Code No.:

A) Batch No. & Date of Manufacture :

Quantity:

Date of Receipt :

i) Job Order Number:

h) BIS seal:

i) IO's Signature:

n) Party Ref. No.:

j) Any other Information/Expiry date.if any :

k) Date of Commencement of Testing: I) Date of Completion of Testing:

m) Embossing/Printing:

15 Meters + 5 meters + 5 meters + 5 meters (Approx.)

06.02.2015 15021604

INTACT/ NOT INTACT/ NOT SEALED NIL

Signed/Unsigned NIL

23.02.2015 14.03.2015

FINECAB XLPE 90 3Cx90+1Cx70+1Cx16 SQ.MM. 2015

FWCPL/2014-2015/D.NO.362 Dated: 31.01.2015

PART B: SUPPLEMENTARY INFORMATIONS

a) Reference to sampling procedure, wherever applicable :

b) Supporting documents for the measurements taken and results derived like graphs, tables, sketches and/or photographs, as appropriate to test report, if any[To be attached]:

c) Deviation from the test methods as prescribed in relevant ISS/ work instructions, if any :

MANOHAR SINGH JADON

Issued Ry

Calib Delhi-110035

SADHANA JADON (Quality Manager)

N.A.

NIL

NIL



AMIL 1521 AND CHRIBKALION CENTRE

(BIS/NABL ACCREDITED LABORATORY)

19/168, Sarai Rohilla, Old Rohtak Road, Near Shastri Nagar Metro & Usha Mata Mandir, Delhi-110035 Tel. 011-23643995, Fax: 011-23643992 (M) 9582782444, Email: info@atncc.in; amittestcc@gmail.com

TEST REPORT

IS: 14255-1995

PART C. TEST RESULTS REPORT NO: ATCC2015031903

SI.No.	TESTS/ CL. REF.	SPECIFIED REQUIREMENTS	RESULTS	
1	Test on phase/ Street Light conductors Cls. 4.1, 6.1 & 10			
1.1	Tensile test Cls. 10.1, Cls.6.2.1 of IS 8130-1984 IS 10810(Part-2)			
	Phase	H2 Grade Above 100 and up to and including 150 N/mm ² or H4 Grade Above 150 N/mm ²	H2 Grade 130.3	
1.2	Street Light N/mm² or H4 Grade Above 150 N/mm² 134.5			
	Phase Street Light	The wires not break during the test	Satisfactory Satisfactory	
1.3	Flexibility Cl. 6.1 & Cl. 4.1 (a) of IS 8130:1984	Class-1/Class-2	Class 2	
1.4	Nature and Shape of Conductor Cl. 4.1	Stranded Circular/Compacted Circular	Compacted Circular	
1.5	No. of wires in Conductor CI 5.3.3, Table 2 of IS 8130:1984 Phase Street Light	15 (Min.)	19	
1.6				
	Phase I Phase II Phase III	At 20°C 0.320 Ohm/km Max.	0.302 0.304 0.302	
2	Street Light Test on Messenger conductor	1.91 Ohm/km Max.	1.84	
2.1	Cls. 4.2, 6.2 & 10 Elongation test (Before Stranding) Cls. 10.1 & 11.3, IS 10810(Part-2)	4% Min.	5.5	
2.2	Breaking load test (After Stranding) Cls. 10.1 & (table-3), IS 10810(Part-2)	19.70 kN Min.	20.25	
	Conductor Resistance test Cls. 10.1 & (table-3), IS 10810(Part-5)	At 20°C 0.492 Ohm/km Max.	0.478	
500	Insulation Cls.5.1	The insulation shall be either of cross-linked polyethylene compound or of polyethylene compound	Cross-Linked Polyethylene	
	Construction of conductor As per Cls.6			
	Cls.6.1	The power/Outer insulated neutral/street lighting Conductor should be flexibility class-2 of as per IS:8130-1984	Class-2	
4.2	Cls.6.2	The messenger conductor should be either stranded circular or compacted circular type and shall have min. 7 strands. The surface of the conductor should be smooth	Circular Compacted Messenger 7	
			Strands	

MANOHAR SINGH JADON

19 03 2015 Issued By (C.E.O.) Delni-110035

SADHANA JA DODANORY

2 of 6



(BIS/NABL ACCREDITED LABORATORY)

19/168, Sarai Rohilla, Old Rohtak Road, Near Shastri Nagar Metro & Usha Mata Mandir, Delhi-110035 Tel. 011-23643995, Fax: 011-23643992 (M) 9582782444, Email: info@atncc.in; amittestcc@gmail.com

TEST REPORT

REPORT NO: ATCC2015031903

IS: 14255-1995

SI.No.	TESTS/ CL. REF.	SPECIFIED REQUIREMENTS	RESULTS
4.3	Cls.6.3	A protective barrier may be applied between the conductors and insulation. If required	N.A.
4.4	Cls.6.4	The size of street lighting conductor should be 16 mm ²	16
4.5	Cls.6.5 & Table -3	The size of messenger conductor for single phase and three phase cable and its breaking load and maximum dc resistance shall be as per Table 3	70 mm ²
4.6	Cls.6.6	There should be no joints in any wire of the messenger conductor except those made in the base rod of wires before final drawing. The direction of Outer layer of wires in messenger conductor should be right hand	conductor
5	Insulation Cl. 7		Right Hand
5.1	CI. 7.1	The conductor (with protective barrier, wherever applied) shall be provided with cross linked polyethylene or polyethylene insulation applied by extrusion.	Cross Linked Polyethylene by Extrusion
5.2	Application of Insulation Cl. 7.4	The insulation shall be so applied that it fits closely on the conductor (or barrier, if any) and it shall be possible to remove it without damaging the conductor	Satisfactory
	Colour of Insulation Cl. 7.5	The colour of insulation shall be black	Black
	Core identification		
}	Cl. 8.1	The phase conductors shall be provided with one, two or three 'ridges' and outer neutral insulated conductor, if provided, shall have four 'ridges' for quick identification. The street lightning conductor and messenger conductor (if insulated) shall not have any identification	Satisfactory
	Cl. 8.2	The single phase conductor shall be provided with 'One Ridge' and if neutral insulated conductor is provided shall have 'Four Ridges' for quick identification. The street Light Conductor & Messenger Conductor (if insulated) shall not have any identification mark.	N.A.
6.3	CI. 8.3	Identification by other means, as agreed between the supplier and purchaser, is also permissible.	N.A.

MANOHAR SINGH JADON

leguad Ry

19/03/2015 (C.E.O.)

Calibra Delhi-110035

SADHANA JADON (Quality Manager)



(BIS/NABL ACCREDITED LABORATORY)

19/168, Sarai Rohilla, Old Rohtak Road, Near Shastri Nagar Metro & Usha Mata Mandir, Delhi-110035 Tel. 011-23643995, Fax: 011-23643992 (M) 9582782444, Email: info@atncc.in; amittestcc@gmail.com

TEST REPORT

REPORT NO: ATCC2015031903

IS: 14255-1995

SI.No.	TESTS/ CL. REF.	SPECIFIED REQUIREMENTS	RESULTS		
7	Assembly (Laying up)				
7.1	Cl. 9.1	Three insulated phase conductors, one insulated neutral conductor (if required) and a street lighting conductor (if required) shall be twisted around the bare (or insulated) as required messenger conductor without fillers with a lay not exceeding 35 times the diameter of the insulated phase conductor.	32.5		
7.2	Cl. 9.2	Single insulated phase conductor, one insulated neutral conductor (if required) and a Street Lighting Conductor (if required) shall be twisted around the bare (or insulated) as required Messenger Conductor without filler with a lay not exceeding 35 times the diameter of the insulated phase conductor.	N.A.		
7.3	Cl. 9.3	The direction of lay shall be right hand.	Right Hand		
8 Physical test for XLPE insulation					
	Cls. 5.7 & 10				
8.1	Tensile strength & Elongation at break (before Ageing)				
	Cls. 10.1& (Table-1), IS 10810(Part-7)				
	Tensile strength Phase I Phase II Phase III Street Light	12.5 N/mm ² Min.	17.95 17.42 18.15 17.65		
3.1.2	Elongation at break Phase I Phase II Phase III Street Light	200% (Min.)	510 490 483 478		
	After ageing in Air oven Cls. 10.1& (Table-1), IS 10810(Part-11)	\$			
8.2.1	Tensile strength Variation Phase I Phase II Phase III Street Light	<u>+</u> 25 % Max.	-7.55 -8.62 -7.90 -6.85		
8.2.2	Elongation at break Variation Phase I Phase II Phase III Street Light	<u>+</u> 25 % Max.	-5.88 -5.51 -5.80 -6.28		

MANOHAR SINGH JADON

Issued By

Moder 19 03 2015 (C.E.O.) Delhi-110035

SADHANA JADON
(Quality Manager)

Authorized Signatory

A of G



t and calibration centre

(BIS/NABL ACCREDITED LABORATORY)

19/168, Sarai Rohilla, Old Rohtak Road, Near Shastri Nagar Metro & Usha Mata Mandir, Delhi-110035 Tel. 011-23643995, Fax: 011-23643992 (M) 9582782444, Email: info@atncc.in; amittestcc@gmail.com

TEST REPORT

REPORT NO: ATCC2015031903

IS: 14255-1995

SI.No.	TESTS/ CL. REF.	SPECIFIED REQUIREMENTS	RESULTS	
8.3	Shrinkage test			
	Cls. 10.1& (Table-1), IS 10810(Part-12)			
	Phase I	40/ 84	1.5	
	Phase II	4% Max.	1.5	
	Phase III		1.0	
	Street Light		1.0	
8.4	Water Absorption test (Gravimetric)			
	Cls. 10.1& (Table-1), IS 10810(Part-33)			
	Phase I		0.018	
	Phase II	1 mg/cm ² Max.	0.022	
	Phase III		0.024	
	Street Light	, a , a + 18 m,	0.021	
8.5	Hot set test			
	Cls. 5.1& (Table-1) , IS 10810(Part-30)			
8.5.1	Elongation under load			
	Phase I	175% Max.	76.20	
	Phase II		82.45	
	Phase III		86.60	
	Street Light		84.65	
	Permanent Elongation(set)after cooling			
- 1	Phase I		1.85	
	Phase II	15% Max.	2.30	
	Phase III	1376 IVIAX.	3.75	
	Street Light		2.15	
	Test for thickness of insulation			
	Cls.7,10.1&(Table-4), IS 10810(Part-6)			
-	Phase conductors		Nom. Mi	
- 1	Phase I	Nominal 1.50 mm	1.62 1.5	
	Phase II	Min. 1.25 mm	1.60 1.5	
-	Phase III		1.58 1.5	
1	Street Light	Nominal 1.20 mm		
		Min. 0.98 mm	1.28 1.1	
	Insulation resistance test (Volume resistivity)			
	Cls. 10.1& (Table-1), IS 10810(Part-43)			
10.1	Volume resistivity at 27°C			
	Phase I		4.18 x 10 ¹	
1	Phase II	1x10 ¹³ Ohm-cm Min.	4.85 x 10 ¹	
	Phase III	2000 Z	5.65 x 10 ¹	
	Street Light		5.65 X 10 ⁻¹	
0.2	At 70°C		5.10 X 10	
	Phase I		0.00 4-1	
	Phase II	1x10 ¹¹ Ohm-cm Min.	2.90 x 10 ¹	
	Phase III	TATO CHIN-CHI WIII.	3.40 x 10 ¹ 3.18 x 10 ¹	

MANOHAR SINGH JADON

Issued By

and Calibr Delhi-110035





(BIS/NABL ACCREDITED LABORATORY)

19/168, Sarai Rohilla, Old Rohtak Road, Near Shastri Nagar Metro & Usha Mata Mandir, Delhi-110035 Tel. 011-23643995, Fax: 011-23643992 (M) 9582782444, Email: info@atncc.in; amittestcc@gmail.com

TEST REPORT

REPORT NO: ATCC2015031903

IS: 14255-1995

SI.No.	TESTS/ CL. REF.	SPECIFIED REQUIREMENTS	RESULTS
Cls. 10.10 Phase I Phase III	High voltage test Cls. 10.1& 11.2, IS 10810(Part-45)	At room temperature the cable shall withstand a	AC Voltage
	Phase II	voltage of 3 kV ac (rms) at a frequency of 40 to 60 Hz. or a dc voltage of 7.2 kV between conductors for 5 minutes	Withstood Withstood Withstood Withstood
12	Optional test Cls. 10.4, IS 10810(Part-50)		WILLISTOOG
	Bending test Cls. 11.4	No cracks visible to naked eye	Satisfactory
13	Aluminium Alloy wire, Chemical Composition Cl. 4.2		
13.1	Magnesium	0.5% Approx.	0.52
13.2	Silicon	0.5% Approx.	0.53

PART D REMARKS: The Sample conforms to various requirements specified in IS: 14255-1995 with

amendments no. 1

Note: Any deviation from the standard, test method/specification- NIL

XXXXXXXXX END OF TEST REPORT XXXXXXXXXX

MANOHAR SINGH JADON

M&don 19/03/20/5.E.O.)

Issued By

Delhi-110035

SADHANA JADON
(Quality Manager)
Authorized Signatory

6 of 6

Notes:

(1). This Test Report refers only to the particular sample(s) submitted for testing. (2) This Test Report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the CEO, Amit Test and Calibration Centre, New Delhi. (3) Test Report shall not be utilized for any legal purpose and will not be produced in the court of law & no responsibility would be attached Amit Test and Calibration Centre. (4) The test results reported in this certificate are valid at the time at the time of and under the stated conditions of measurements



(BIS/NABL ACCREDITED LABORATORY)

19/168, Sarai Rohilla, Old Rohtak Road, Near Shastri Nagar Metro & Usha Mata Mandir, Delhi-110035 Tel. 011-23643995, Fax: 011-23643992 (M) 9582782444, Email: info@atncc.in; amittestcc@gmail.com

TEST REPORT

REPORT NO: ATCC2014081103

IS: 191-2007

SL.NO.	TESTS/ CL. REF.	SPECIFIED REQUIREMENTS	RESULTS
18	Copper purity test IS:191-2007 & 440-1964 Cls. 7.1 & (table-4)		
		Cu - ETP Cu - FRHC	
18.1	Copper + Silver, % by mass	99.90 Min. 99.90 Min.	99.94
18.2	Bismuth, (ppm)	10 Max. 10 Max.	6
18.3	Lead, % by mass	0.005 Max. 0.005 Max.	0.004
18.4	Oxygen, % by mass	0.045 Max 0.045 Max	0.036
18.5	Total of all Impurities excluding silver & oxygen, % by mass	0.03 Max. 0.03 Max.	< 0.03

PART D REMARKS: The Sample conforms to various requirements specified in IS: 694/1990 with amendments No.1,2,3,4 & 5 and IS 191-2007, IS 440 - 1964.

Note: Any Deviation from the Standard, Test method/Specification - NIL

MANOHAR SINGH JADON
Modow

11 0 8 2014 (C.E.O.) Delhi-110035

SADHANA JADON (Quality Manager)

Authorized Signatory

7 of 7

Votes:

1). This Test Report refers only to the particular sample(s) submitted for testing. (2) This Test Report shall not be eproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from he CEO, Amit Test and Calibration Centre, New Delhi.(3)Test Report shall not be utilized for any legal purpose and will not be produced in the court of law & no responsibility would be attached Amit Test and Calibration Centre.(4) The test results reported in this certificate are valid at the time at the time of and under the stated and title and the stated are distinct.